

TSTRANSCO Transmission Losses for the month of November 2016					
EBC Data					
	INPUT		OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	1362.20	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1346.49	TSSPDCL	2895.64	
	HYDEL	15.70	TSNPDCL	1100.79	
C.G.S			Total	3996.42	
	CGS (Injection at TS-Periphery)	2064.77			
CPPs	TOTAL	152.79			
	132KV My Home Cements I & II	19.04			
	HWP	1.77			
	Kesoram	0.00			
	NBFA # 1 & 2	18.25			
	Sitapuram Power Limited	11.15			
	Madhucon SPIL 132 kV Kusumanchi	4.50			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	12.99			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	0.00			
	Krishnaveni sugars	7.47			
	132KV Laxmi Tulasi	6.37			
	Orient Cement 132 kV	0.00			
	NBEIL #1	31.13			
	NBEIL #2	31.11			
	ICL (Rassi Cements)	8.81			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	0.18			
Non-Conventional (132 Kv PDs)	TOTAL	81.74			
	Clean solar	4.28			
	Dayakara Solar (P) Ltd.	4.36			
	Enrich (Solar)	8.03			
	G.S.R.Sugars Pvt Ltd	-0.08			
	Ganapathi Sugars Ltd.	0.49			
	Grahati Solar	5.14			
	Kakatiya Cement & Sugar Industries Ltd.	0.09			
	Karvy solar	1.39			
	My Home Power Ltd. (NGPL)	0.00			
	Mytrah Vayu (Godavari) Pvt. Ltd. (Wind)	15.08			
	NTPC Solar power plant (10MW)	1.37			
	Nizam Deccan Sugars Ltd.	0.00			
	Polepally Solar Park	3.89			
	Renue Akshay Solar Plant	16.19			
	SLS Power Corp. Ltd.	6.87			
	Shravana Power Projects Pvt. Ltd.	-0.02			
	Sunborne Energy Tech. (P) Ltd. (Solar)	6.60			
	Win solar	2.65			
	Renew Solar Plant (Mdk. Dist.)	4.06	Losses	MU	%
	Ujvalatejas Solaire Urja Pvt. Ltd.	1.32			
IPPs	Singareni Thermal Power Project Ltd. (Jaipur)	478.74	With in State	143.81	3.47
	TOTAL INPUT	4140.23	Total Losses	143.81	3.47
* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th December 2016 to 24.00'hours of 25th January 2017					
* The Transmission Losses are worked out by using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st November 2016 to 24.00 Hr of 30th November 2016 at 00.30 Hr interval.					
* The SR Losses (External Losses to TSTRANSCO) for the month of November 2016 is 2.318%					
* Cumulative losses at TS-Periphery FY 2016-17 is 3.39 %					