

TSTRANSCO Transmission Losses for the month of AUGUST 2014				
EBC Data				
		INPUT	OUTPUT	
		NET ENERGY in MU	DISCOM	MU
TSGENCO	TOTAL	1890.53	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders	
	THERMAL	1180.78	TSSPDCL	2833.05
	HYDEL	709.75	TSNPDCL	1143.95
C.G.S			Total	3976.99
	CGS (Injection at TS-Periphery)	1986.82		
IPPs	TOTAL	7.50		
	SLS Power Corp. Ltd.	7.50		
CPPs	TOTAL	220.34		
	132KV My Home Cements I & II	20.91		
	HWP	7.22		
	Kesoram	0.00		
	NBFA # 1 & #2	39.58		
	Sitapuram Power Limited	15.33		
	Madhucon SPIL 132 kV Kusumanchi	16.07		
	BPL 132 kV Sitharampatnam	0.00		
	Penna Power Limited 132KV Ganeshpahadu#2	26.35		
	Shalivahana (MSW) Green Energy Pvt. Ltd.	4.65		
	Krishnaveni sugars	14.73		
	132KV Laxmi Tulasi	4.52		
	Orient Cement 132 kV	1.39		
	NBEIL #1	30.21		
	NBEIL #2	30.08		
	ICL (Rassi Cements)	8.46		
	PSR Green Power Proj. pvt. Ltd.	0.83		
	KCP	0.00		
Non-Conventional (132 Kv PDs)	TOTAL	11.66		
	G.S.R.Sugars Pvt Ltd	-0.06		
	Ganapathi Sugars Ltd.	-0.10		
	Kakatiya Cement & Sugar Industries Ltd.	9.78		
	Nagarjuna Green Power Ltd. (NGPL)	0.01		
	Nizam Deccan Sugars Ltd.	-0.18		
	Shravana Power Projects Pvt. Ltd.	2.20		
			Losses	MU
			With in State	139.85
	TOTAL INPUT	4116.84	Total Losses	139.85
				3.40
*Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th Sept 2014 to 24.00'hours of 25th Oct. 2014				
* The Transmission Losses are worked out using MRI data.				
* MRI Data considered is from 00.00 Hr of 1st August 2014 to 24.00 Hr of 31st August 2014 at 00.30 Hr interval.				
* The SR Losses (External Losses to TSTRANSCO) for the month of August 2014 is 4.97%				
* Cummlative losses at TS-Peiphery FY2014-15 from June 2014 is 3.49 %				