

## TSTRANSCO Transmission Losses for the month of December 2015

### EBC Data

INPUT		NET ENERGY in MU	OUTPUT		
			DISCOM	MU	
<b>TSGENCO</b>	<b>TOTAL</b>	<b>1139.89</b>	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1109.59	TSSPDCL	2760.10	
	HYDEL	30.30	TSNPDCL	1079.00	
<b>C.G.S</b>			<b>Total</b>	<b>3839.10</b>	
	CGS ( Injection at TS-Periphery)	<b>2545.84</b>			
<b>CPPs</b>	<b>TOTAL</b>	<b>247.19</b>			
	132KV My Home Cements I & II	22.19			
	HWP	6.26			
	Kesoram	0.00			
	NBFA # 1 & 2	52.21			
	Sitapuram Power Limited	15.19			
	Madhucon SPIL 132 kV Kusumanchi	13.68			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	22.97			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	4.57			
	Krishnaveni sugars	11.18			
	132KV Laxmi Tulasi	6.88			
	Orient Cement 132 kV	0.76			
	NBEIL #1	42.31			
	NBEIL #2	42.44			
	ICL (Rassi Cements)	6.46			
	PSR Green Power Proj. Pvt. Ltd.	0.00			
	Deccan cements	0.09			
<b>Non- Conventional (132 Kv PDs)</b>	<b>TOTAL</b>	<b>30.73</b>			
	G.S.R.Sugars Pvt Ltd	4.97			
	Ganapathi Sugars Ltd.	6.78			
	Kakatiya Cement & Sugar Industries Ltd.	7.90			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Nizam Deccan Sugars Ltd.	-0.04			
	SLS Power Corp. Ltd.	2.92			
	Shravana Power Projects Pvt. Ltd.	1.01			
	Enrich (Solar)	7.18	<b>Losses</b>	<b>MU</b>	<b>%</b>
			With in State	124.56	3.14
	<b>TOTAL INPUT</b>	<b>3963.65</b>	<b>Total Losses</b>	<b>124.56</b>	<b>3.14</b>

\* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th January 2016 to 24.00'hours of 25th February 2016

\* The Transmission Losses are worked out by using MRI data.

\* MRI Data considered is from 00.00 Hr of 1st December 2015 to 24.00 Hr of 31st December 2015 at 00.30 Hr interval.

\* The SR Losses (External Losses to TSTRANSCO) for the month of December 2015 is 3.359%

\* Cumulative losses at TS-Periphery FY 2015-16 is 3.10 %