

| <b>TSTRANSCO Transmission Losses for the month of February 2015</b>   |   |                         |   |                |             |
|---|---|-------------------------|---|----------------|-------------|
| <b>EBC Data</b>   |   |                         |   |                |             |
|   |   | <b>INPUT</b>            | <b>OUTPUT</b>   |                |             |
|   |   | <b>NET ENERGY in MU</b> | <b>DISCOM</b>   | <b>MU</b>      |             |
| <b>TSGENCO</b>  | <b>TOTAL</b>                                  | <b>1312.04</b>          | 220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders |                |             |
|   | THERMAL                                       | 1236.85                 | TSSPDCL   | 2596.79        |             |
|   | HYDEL   | 75.19                   | TSNPDCL   | 1068.43        |             |
| <b>C.G.S</b>  |   |                         | <b>Total</b>  | <b>3665.23</b> |             |
|   | CGS ( Injection at TS-Periphery)              | <b>2209.26</b>          |   |                |             |
| <b>CPPs</b>   | <b>TOTAL</b>                                  | <b>230.23</b>           |   |                |             |
|   | 132KV My Home Cements I & II                  | 24.46                   |   |                |             |
|   | HWP   | 6.53                    |   |                |             |
|   | Kesoram                                       | 1.21                    |   |                |             |
|   | NBFA # 1 & 2                                  | 48.53                   |   |                |             |
|   | Sitapuram Power Limited                       | 19.60                   |   |                |             |
|   | Madhucon SPIL 132 kV Kusumanchi               | 12.22                   |   |                |             |
|   | BPL 132 kV Sitharampatnam                     | 0.00                    |   |                |             |
|   | Penna Power Limited 132KV Ganeshpahadu #1 & 2 | 35.37                   |   |                |             |
|   | Shalivahana (MSW) Green Energy Pvt. Ltd.      | 5.26                    |   |                |             |
|   | Krishnaveni sugars                            | 10.79                   |   |                |             |
|   | 132KV Laxmi Tulasi                            | 5.87                    |   |                |             |
|   | Orient Cement 132 kV                          | 1.18                    |   |                |             |
|   | NBEIL #1                                      | 28.31                   |   |                |             |
|   | NBEIL #2                                      | 28.72                   |   |                |             |
|   | ICL (Rassi Cements)                           | 2.14                    |   |                |             |
|   | PSR Green Power Proj. pvt. Ltd.               | 0.00                    |   |                |             |
|   | Deccan cements                                | 0.02                    |   |                |             |
| <b>Non-Conventional (132 Kv PDs)</b>  | <b>TOTAL</b>                                  | <b>21.54</b>            |   |                |             |
|   | G.S.R.Sugars Pvt Ltd                          | 3.71                    |   |                |             |
|   | Ganapathi Sugars Ltd.                         | 6.88                    |   |                |             |
|   | Kakatiya Cement & Sugar Industries Ltd.       | 5.39                    |   |                |             |
|   | Nagarjuna Green Power Ltd. (NGPL)             | 0.01                    |   |                |             |
|   | Nizam Deccan Sugars Ltd.                      | -0.12                   |   |                |             |
|   | SLS Power Corp. Ltd.                          | 2.53                    |   |                |             |
|   | Shravana Power Projects Pvt. Ltd.             | 3.14                    |   |                |             |
|   |   |                         | <b>Losses</b>   | <b>MU</b>      | <b>%</b>    |
|   |   |                         | With in State   | 107.84         | 2.86        |
|   | <b>TOTAL INPUT</b>                            | <b>3773.07</b>          | <b>Total Losses</b>   | <b>107.84</b>  | <b>2.86</b> |
| * Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th Mar 2015 to 24.00'hours of 25th April 2015 |   |                         |   |                |             |
| * The Transmission Losses are worked out by using MRI data.   |   |                         |   |                |             |
| * MRI Data considered is from 00.00 Hr of 1st February 2015 to 24.00 Hr of 28th February 2015 at 00.30 Hr interval.                 |   |                         |   |                |             |
| * The SR Losses (External Losses to TSTRANSCO) for the month of February 2015 is 4.94 %   |   |                         |   |                |             |
| * Cummlative losses at TS-Periphery FY2014-15 from June 2014 is 3.17 %  |   |                         |   |                |             |