

TSTRANSCO Transmission Losses for the month of February 2016

EBC Data

INPUT		NET ENERGY in MU	OUTPUT		
			DISCOM	MU	
TSGENCO	TOTAL	1214.33	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1171.16	TSSPDCL	2743.63	
	HYDEL	43.17	TSNPDCL	1106.01	
C.G.S			Total	3849.64	
	CGS (Injection at TS-Periphery)	2555.98			
CPPs	TOTAL	175.82			
	132KV My Home Cements I & II	21.03			
	HWP	0.65			
	Kesoram	0.00			
	NBFA # 1 & 2	41.87			
	Sitapuram Power Limited	16.72			
	Madhucon SPIL 132 kV Kusumanchi	9.85			
	BPL 132 kV Sitharampatnam	0.01			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	22.43			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	4.26			
	Krishnaveni sugars	9.03			
	132KV Laxmi Tulasi	5.33			
	Orient Cement 132 kV	0.01			
	NBEIL #1	17.58			
	NBEIL #2	17.60			
	ICL (Rassi Cements)	9.45			
	PSR Green Power Proj. Pvt. Ltd.	0.00			
	Deccan cements	0.00			
Non- Conventional (132 Kv PDs)	TOTAL	34.63			
	G.S.R.Sugars Pvt Ltd	4.51			
	Ganapathi Sugars Ltd.	7.14			
	Kakatiya Cement & Sugar Industries Ltd.	7.37			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Nizam Deccan Sugars Ltd.	-0.04			
	SLS Power Corp. Ltd.	0.92			
	Shravana Power Projects Pvt. Ltd.	3.85			
	Enrich (Solar)	7.17	Losses	MU	%
	Sunborne Energy Tech. (P) Ltd. (Solar)	3.71	With in State	131.13	3.29
	TOTAL INPUT	3980.76	Total Losses	131.13	3.29

* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th March 2016 to 24.00'hours of 25th April 2016

* The Transmission Losses are worked out by using MRI data.

* MRI Data considered is from 00.00 Hr of 1st February 2016 to 24.00 Hr of 29th February 2016 at 00.30 Hr interval.

* The SR Losses (External Losses to TSTRANSCO) for the month of January 2016 is 3.19%

* Cumulative losses at TS-Periphery FY 2015-16 is 3.12 %