

**TSTRANSCO Transmission Losses for the month of January 2016**

**EBC Data**

INPUT		NET ENERGY in MU	OUTPUT		
			DISCOM	MU	
<b>TSGENCO</b>	<b>TOTAL</b>	<b>960.84</b>	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	960.66	TSSPDCL	2693.73	
	HYDEL	0.18	TSNPDCL	1094.16	
<b>C.G.S</b>			<b>Total</b>	<b>3787.89</b>	
	CGS ( Injection at TS-Periphery)	<b>2676.37</b>			
<b>CPPs</b>	<b>TOTAL</b>	<b>238.69</b>			
	132KV My Home Cements I & II	24.70			
	HWP	5.56			
	Kesoram	0.00			
	NBFA # 1 & 2	48.75			
	Sitapuram Power Limited	23.91			
	Madhucon SPIL 132 kV Kusumanchi	11.37			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	22.93			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	3.69			
	Krishnaveni sugars	10.59			
	132KV Laxmi Tulasi	6.26			
	Orient Cement 132 kV	0.76			
	NBEIL #1	37.15			
	NBEIL #2	37.23			
	ICL (Rassi Cements)	5.45			
	PSR Green Power Proj. Pvt. Ltd.	0.00			
	Deccan cements	0.35			
<b>Non-Conventional (132 Kv PDs)</b>	<b>TOTAL</b>	<b>31.82</b>			
	G.S.R.Sugars Pvt Ltd	4.67			
	Ganapathi Sugars Ltd.	7.78			
	Kakatiya Cement & Sugar Industries Ltd.	6.61			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Nizam Deccan Sugars Ltd.	-0.03			
	SLS Power Corp. Ltd.	1.57			
	Shravana Power Projects Pvt. Ltd.	4.00			
	Enrich (Solar)	7.21	<b>Losses</b>	<b>MU</b>	<b>%</b>
	<b>Sunborne Energy Tech. (P) Ltd. (Solar)</b>	<b>0.00</b>	With in State	119.83	3.07
	<b>TOTAL INPUT</b>	<b>3907.72</b>	<b>Total Losses</b>	<b>119.83</b>	<b>3.07</b>

\* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th February 2016 to 24.00'hours of 25th March 2016

\* The Transmission Losses are worked out by using MRI data.

\* MRI Data considered is from 00.00 Hr of 1st January 2016 to 24.00 Hr of 31st January 2016 at 00.30 Hr interval.

\* The SR Losses (External Losses to TSTRANSCO) for the month of January 2016 is 2.73%

\* Cummilative losses at TS-Periphery FY 2015-16 is 3.10 %