

**TSTRANSCO Transmission Losses for the month of July 2014**

**EBC Data**

		INPUT	OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	1299.36	220kV/33kV,132kV/33kV,132 /11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1250.87	TSSPDCL	2642.29	
	HYDEL	48.49	TSNPDCL	1014.12	
C.G.S			Total	3656.41	
	CGS ( Injection at TS-Periphery)	2217.27			
IPPs	TOTAL	2.99			
	SLS Power Corp. Ltd.	2.99			
CPPs	TOTAL	258.76			
	132KV My Home Cements I & II	20.79			
	HWP	8.23			
	Kesoram	0.00			
	NBFA # 1 & #2	37.17			
	Sitapuram Power Limited	20.51			
	Madhucon SPIL 132 kV Kusumanchi	15.79			
	BPL 132 kV Sitharampatnam	0.01			
	Penna Power Limited 132KV Ganeshpahadu#2	28.41			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	5.74			
	Krishnaveni sugars	7.55			
	132KV Laxmi Tulasi	4.83			
	Orient Cement 132 kV	0.01			
	NBEIL #1	47.45			
	NBEIL #2	47.41			
	ICL (Rassi Cements)	13.72			
	PSR Green Power Proj. Pvt. Ltd.	1.14			
	KCP	0.00			
Non-Conventional (132 Kv PDs)	TOTAL	13.07			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.11			
	Kakatiya Cement & Sugar Industries Ltd.	9.54			
	Nagarjuna Green Power Ltd. (NGPL)	0.01			
	Nizam Deccan Sugars Ltd.	-0.16			
	Shravana Power Projects Pvt. Ltd.	3.83			
			Losses	MU	%
			With in State	135.05	3.56
	TOTAL INPUT	3791.46	Total Losses	135.05	3.56

\*Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th August 2014 to 24.00'hours of 25th Sept. 2014

\* The Transmission Losses are worked out using MRI data.

\* MRI Data considered is from 00.00 Hr of 1st July 2014 to 24.00 Hr of 31st July2014 at 00.30 hr interval.

\* The SR Losses (External Losses to TSTRANSCO) for the month of July 14 is 3.56%

\* Cumulative losses at TS-Peiphery FY2014-15 from June 2014 is 3.54 %