

TSTRANSCO Transmission Losses for the month of July 2015

EBC Data

INPUT		NET ENERGY in MU	OUTPUT		
			DISCOM	MU	
TSGENCO	TOTAL	1170.19	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1172.92	TSSPDCL	2980.13	
	HYDEL	-2.73	TSNPDCL	1149.97	
C.G.S			Total	4130.10	
	CGS (Injection at TS-Periphery)	2846.84			
CPPs	TOTAL	228.04			
	132KV My Home Cements I & II	23.10			
	HWP	5.52			
	Kesoram	1.15			
	NBFA # 1 & 2	33.88			
	Sitapuram Power Limited	19.78			
	Madhucon SPIL 132 kV Kusumanchi	10.79			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	23.90			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	4.48			
	Krishnaveni sugars	12.39			
	132KV Laxmi Tulasi	2.75			
	Orient Cement 132 kV	0.96			
	NBEIL #1	40.80			
	NBEIL #2	41.18			
	ICL (Rassi Cements)	6.96			
	PSR Green Power Proj. Pvt. Ltd.	0.00			
	Deccan cements	0.39			
Non-Conventional (132 Kv PDs)	TOTAL	16.58			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.08			
	Kakatiya Cement & Sugar Industries Ltd.	1.27			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Nizam Deccan Sugars Ltd.	-0.14			
	SLS Power Corp. Ltd.	7.38			
	Shravana Power Projects Pvt. Ltd.	4.28			
	Enrich (Solar)	3.94	Losses	MU	%
			With in State	131.54	3.09
	TOTAL INPUT	4261.64	Total Losses	131.54	3.09

* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th August 2015 to 24.00'hours of 25th September 2015

* The Transmission Losses are worked out by using MRI data.

* MRI Data considered is from 00.00 Hr of 1st July 2015 to 24.00 Hr of 31st July 2015 at 00.30 Hr interval.

* The SR Losses (External Losses to TSTRANSCO) for the month of July 2015 is 2.954%

* Cumulative losses at TS-Periphery FY 2015-16 is 3.19 %