

TSTRANSCO Transmission Losses for the month of June 2015					
EBC Data					
	INPUT		OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	867.06	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	869.77	TSSPDCL	2578.44	
	HYDEL	-2.71	TSNPDCL	776.92	
C.G.S			Total	3355.36	
	CGS (Injection at TS-Periphery)	2372.10			
CPPs	TOTAL	215.60			
	132KV My Home Cements I & II	14.34			
	HWP	4.17			
	Kesoram	0.36			
	NBFA # 1 & 2	54.50			
	Sitapuram Power Limited	15.16			
	Madhucon SPIL 132 kV Kusumanchi	8.26			
	BPL 132 kV Sitharampatnam	0.01			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	25.54			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	3.01			
	Krishnaveni sugars	3.26			
	132KV Laxmi Tulasi	2.46			
	Orient Cement 132 kV	0.45			
	NBEIL #1	39.60			
	NBEIL #2	39.62			
	ICL (Rassi Cements)	4.53			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	0.32			
Non-Conventional (132 Kv PDs)	TOTAL	9.45			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.09			
	Kakatiya Cement & Sugar Industries Ltd.	-0.11			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Nizam Deccan Sugars Ltd.	-0.12			
	SLS Power Corp. Ltd.	2.19			
	Shravana Power Projects Pvt. Ltd.	4.05			
	Enrich (Solar)	3.59	Losses	MU	%
			With in State	108.85	3.14
	TOTAL INPUT	3464.22	Total Losses	108.85	3.14
* Transmission Losses are applicable to OA Users for the period from 00.00*hours of 26th July 2015 to 24.00*hours of 25th August 2015					
* The Transmission Losses are worked out by using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st June 2015 to 24.00 Hr of 30th June 2015 at 00.30 Hr interval.					
* The SR Losses (External Losses to TSTRANSCO) for the month of June 2015 is 3.224%					
* Cummilative losses at TS-Periphery FY 2015-16 is 3.23 %					