

TSTRANSCO Transmission Losses for the month of March 2016					
EBC Data					
	INPUT		OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	1516.90	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1476.97	TSSPDCL	3079.25	
	HYDEL	39.93	TSNPDCL	1194.17	
C.G.S			Total	4273.42	
	CGS (Injection at TS-Periphery)	2628.43			
CPPs	TOTAL	243.27			
	132KV My Home Cements I & II	21.12			
	HWP	1.67			
	Kesoram	0.00			
	NBFA # 1 & 2	49.79			
	Sitapuram Power Limited	21.17			
	Madhucon SPIL 132 kV Kusumanchi	11.55			
	BPL 132 kV Sitharampatnam	0.01			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	26.32			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	4.08			
	Krishnaveni sugars	9.91			
	132KV Laxmi Tulasi	6.59			
	Orient Cement 132 kV	0.02			
	NBEIL #1	41.19			
	NBEIL #2	41.16			
	ICL (Rassi Cements)	8.43			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	0.27			
Non-Conventional (132 Kv PDs)	TOTAL	28.05			
	G.S.R.Sugars Pvt Ltd	0.19			
	Ganapathi Sugars Ltd.	2.82			
	Kakatiya Cement & Sugar Industries Ltd.	7.75			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Mytrah Vayu (Godavari) Pvt. Ltd. (Wind)	0.12			
	Nizam Deccan Sugars Ltd.	-0.04			
	SLS Power Corp. Ltd.	0.69			
	Shravana Power Projects Pvt. Ltd.	1.34			
	Enrich (Solar)	7.57	Losses	MU	%
	Sunborne Energy Tech. (P) Ltd. (Solar)	6.50	With in State	143.23	3.24
	Singareni Thermal Power Project Ltd. (Jaipur)	1.10			
	TOTAL INPUT	4416.65	Total Losses	143.23	3.24
* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th April 2016 to 24.00'hours of 25th May 2016					
* The Transmission Losses are worked out by using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st March 2016 to 24.00 Hr of 31st March 2016 at 00.30 Hr interval.					
* The SR Losses (External Losses to TSTRANSCO) for the month of January 2016 is 3.14%					
* Cummlitative losses at TS-Periphery FY 2015-16 is 3.13 %					