

TSTRANSCO Transmission Losses for the month of May 2015					
EBC Data					
		INPUT	OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	1276.45	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1275.16	TSSPDCL	2862.94	
	HYDEL	1.29	TSNPDCL	883.21	
C.G.S			Total	3746.15	
	CGS (Injection at TS-Periphery)	2313.54			
CPPs	TOTAL	272.67			
	132KV My Home Cements I & II	24.08			
	HWP	5.79			
	Kesoram	0.46			
	NBFA # 1 & 2	57.32			
	Sitapuram Power Limited	14.16			
	Madhucon SPIL 132 kV Kusumanchi	11.76			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	30.09			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	6.23			
	Krishnaveni sugars	15.76			
	132KV Laxmi Tulasi	4.58			
	Orient Cement 132 kV	0.02			
	NBEIL #1	46.55			
	NBEIL #2	46.93			
	ICL (Rassi Cements)	8.02			
	PSR Green Power Proj. Pvt. Ltd.	0.00			
	Deccan cements	0.92			
Non-Conventional (132 Kv PDs)	TOTAL	9.12			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.09			
	Kakatiya Cement & Sugar Industries Ltd.	-0.13			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Nizam Deccan Sugars Ltd.	-0.18			
	SLS Power Corp. Ltd.	0.93			
	Shravana Power Projects Pvt. Ltd.	4.38			
	Enrich (Solar)	4.29	Losses	MU	%
			With in State	125.63	3.24
	TOTAL INPUT	3871.78	Total Losses	125.63	3.24
* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th June 2015 to 24.00'hours of 25th July 2015					
* The Transmission Losses are worked out by using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st May 2015 to 24.00 Hr of 31st May 2015 at 00.30 Hr interval.					
* The SR Losses (External Losses to TSTRANSCO) for the month of March 2015 is 3.52%					
* Cummlative losses at TS-Peiphery FY 2015-16 is 3.27 %					