

TSTRANSCO Transmission Losses for the month of October 2015

EBC Data

INPUT		NET ENERGY in MU	OUTPUT		
			DISCOM	MU	
TSGENCO	TOTAL	1164.78	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1133.32	TSSPDCL	2946.90	
	HYDEL	31.45	TSNPDCL	1398.56	
C.G.S			Total	4345.45	
	CGS (Injection at TS-Periphery)	3037.85			
CPPs	TOTAL	247.57			
	132KV My Home Cements I & II	25.73			
	HWP	6.43			
	Kesoram	0.34			
	NBFA # 1 & 2	36.60			
	Sitapuram Power Limited	16.57			
	Madhucon SPIL 132 kV Kusumanchi	8.25			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	30.77			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	2.36			
	Krishnaveni sugars	13.74			
	132KV Laxmi Tulasi	6.32			
	Orient Cement 132 kV	0.83			
	NBEIL #1	44.27			
	NBEIL #2	44.33			
	ICL (Rassi Cements)	8.37			
	PSR Green Power Proj. Pvt. Ltd.	0.00			
	Deccan cements	2.67			
Non-Conventional (132 Kv PDs)	TOTAL	26.22			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.09			
	Kakatiya Cement & Sugar Industries Ltd.	10.44			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Nizam Deccan Sugars Ltd.	-0.14			
	SLS Power Corp. Ltd.	8.10			
	Shravana Power Projects Pvt. Ltd.	1.61			
	Enrich (Solar)	6.37	Losses	MU	%
			With in State	130.97	2.93
	TOTAL INPUT	4476.42	Total Losses	130.97	2.93

* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th November 2015 to 24.00'hours of 25th December 2015

* The Transmission Losses are worked out by using MRI data.

* MRI Data considered is from 00.00 Hr of 1st October 2015 to 24.00 Hr of 31st October 2015 at 00.30 Hr interval.

* The SR Losses (External Losses to TSTRANSCO) for the month of October 2015 is 2.8786%

* Cummilative losses at TS-Periphery FY 2015-16 is 3.12 %