

TSTRANSCO Transmission Losses for the month of SEPTEMBER 2014				
EBC Data				
		INPUT	OUTPUT	
		NET ENERGY in MU	DISCOM	MU
TSGENCO	TOTAL	2036.35	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders	
	THERMAL	1068.01	TSSPDCL	2781.07
	HYDEL	968.35	TSNPDCL	1190.42
C.G.S			Total	3971.49
	CGS (Injection at TS-Periphery)	1815.81		
CPPs	TOTAL	241.04		
	132KV My Home Cements I & II	19.85		
	HWP	6.71		
	Kesoram	0.00		
	NBFA # 1 & #2	39.27		
	Sitapuram Power Limited	10.80		
	Madhucon SPIL 132 kV Kusumanchi	14.05		
	BPL 132 kV Sitharampatnam	0.00		
	Penna Power Limited 132KV Ganeshpahadu#2	26.83		
	Shalivahana (MSW) Green Energy Pvt. Ltd.	0.00		
	Krishnaveni sugars	14.29		
	132KV Laxmi Tulasi	5.34		
	Orient Cement 132 kV	1.50		
	NBEIL #1	45.11		
	NBEIL #2	44.40		
	ICL (Rassi Cements)	11.79		
	PSR Green Power Proj. pvt. Ltd.	0.00		
	Deccan cements	1.10		
Non-Convention	TOTAL	15.15		
	G.S.R.Sugars Pvt Ltd	-0.06		
	Ganapathi Sugars Ltd.	-0.06		
	Kakatiya Cement & Sugar Industries Ltd.	7.78		
	Nagarjuna Green Power Ltd. (NGPL)	0.01		
	Nizam Deccan Sugars Ltd.	-0.14		
	SLS Power Corp. Ltd.	4.59		
	Shravana Power Projects Pvt. Ltd.	3.03		
			Losses	MU
			With in State	136.86
	TOTAL INPUT	4108.35	Total Losses	136.86
				3.33
*Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th Oct. 2014 to 24.00'hours of 25th Nov. 2014.				
* The Transmission Losses are worked out using MRI data.				
* MRI Data considered is from 00.00 Hr of 1st September 2014 to 24.00 Hr of 30th September 2014 at 00.30Hr interval.				
* The SR Losses (External Losses to TSTRANSCO) for the month of September 2014 is 5.08%				
* Cummilative losses at TS-Peiphery FY2014-15 from June 2014 is 3.45 %				