

TSTRANSCO Transmission Losses for the month of MAY 2017

EBC Data					
	INPUT		OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	1550.61	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1539.01	TSSPDCL	3167.82	
	HYDEL	11.60	TSNPDCL	965.90	
C.G.S			Total	4133.72	
	CGS (Injection at TS-Periphery)	1788.26			
CPPs	TOTAL	130.34			
	132KV My Home Cements I & II	14.63			
	HWP	0.98			
	Kesoram	0.00			
	NBFA # 1 & 2	24.84			
	Sitapuram Power Limited	4.88			
	Madhucon SPIL 132 kV Kusumanchi	0.00			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	7.61			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	0.00			
	Krishnaveni sugars	0.00			
	132KV Laxmi Tulasi	3.18			
	Orient Cement 132 kV	0.00			
	NBEIL #1	31.55			
	NBEIL #2	31.61			
	ICL (Rassi Cements)	10.99			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	0.06			
	Anjani Port Land Cement	0.00			
Non-Conventional (132 Kv PDs)	TOTAL	142.58			
	Clean solar	5.18			
	Dayakara Solar (P) Ltd.	5.81			
	Energion Soleq Pvt Ltd	9.45			
	Energion Soleq Solar (Sadasivapet)	2.72			
	Enrich (Solar)	8.22			
	G.S.R.Sugars Pvt Ltd	-0.05			
	Ganapathi Sugars Ltd.	-0.07			
	Grahati Solar	9.79			
	Kakatiya Cement & Sugar Industries Ltd.	-0.14			
	Karvy solar	2.39			
	My Home Power Ltd. (NGPL)	0.00			
	Mytrah Vayu (Godavari) Pvt. Ltd. (Wind)	17.26			
	NTPC Solar power plant (10MW)	1.47			
	Nizam Deccan Sugars Ltd.	0.00			
	Polepally Solar Park	4.43			
	Renew Mega Solar Pvt.Ltd	9.91			
	Renew Saurshakthi Pvt. Ltd.	5.13			
	Renew Solar Energy Pvt. Ltd. (Dichpally)	10.53			
	Renew Solar Plant (Mdk. Dist.)	4.16			
	Renew Solar Pvt Ltd. (Minpur)	0.06			
	Renue Akshay Solar Plant	17.50			
	SLS Power Corp. Ltd.	0.04			
	Shapoorji Pallonji Energy Pvt Ltd. (Solar)	1.30			
	Shravana Power Projects Pvt. Ltd.	4.44			
	Sunborne Energy Tech. (P) Ltd. (Solar)	6.57	Losses	MU	%
	Suprasanna Solar	3.69			
	Ujjvalatejas Solaire Urja Pvt. Ltd. (Solar)	3.06			
	Winsol solar	6.87			
	Win solar	2.87			
IPPs	Singareni Thermal Power Project Ltd. (Jaipur)	669.14	With in State	147.21	3.44
	TOTAL INPUT	4280.93	Total Losses	147.21	3.44
* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th June 2017 to 24.00'hours of 25th July 2017					
* The Transmission Losses are worked out by using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st May 2017 to 24.00 Hr of 31st May 2017 at 00.30 Hr interval.					
* The SR Losses (External Losses to TSTRANSCO) for the month of May 2017 is 3.244%					
* Cummilative losses at TS-Periphery FY 2017-18 is 3.36 %					