

TSTRANSCO Transmission Losses for the month of April 2016					
EBC Data					
	INPUT		OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	1354.55	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1357.67	TSSPDCL	3085.40	
	HYDEL	-3.12	TSNPDCL	1088.10	
C.G.S			Total	4173.50	
	CGS (Injection at TS-Periphery)	2674.12			
CPPs	TOTAL	265.64			
	132KV My Home Cements I & II	29.67			
	HWP	6.37			
	Kesoram	0.09			
	NBFA # 1 & 2	50.37			
	Sitapuram Power Limited	18.36			
	Madhucon SPIL 132 kV Kusumanchi	12.13			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	27.48			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	3.47			
	Krishnaveni sugars	12.55			
	132KV Laxmi Tulasi	6.54			
	Orient Cement 132 kV	1.39			
	NBEIL #1	43.03			
	NBEIL #2	42.99			
	ICL (Rassi Cements)	10.73			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	0.47			
Non-Conventional (132 Kv PDs)	TOTAL	22.53			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.08			
	Kakatiya Cement & Sugar Industries Ltd.	1.10			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Mytrah Vayu (Godavari) Pvt. Ltd. (Wind)	4.98			
	Nizam Deccan Sugars Ltd.	-0.01			
	SLS Power Corp. Ltd.	-0.05			
	Shravana Power Projects Pvt. Ltd.	-0.02			
	Enrich (Solar)	7.80			
	Sunborne Energy Tech. (P) Ltd. (Solar)	6.65			
	Karvy solar	0.04			
	Polepally Solar Park	0.10			
	Renue Akshay Solar Plant	2.08	Losses	MU	%
IPPs	Singareni Thermal Power Project Ltd. (Jaipur)	-0.12	With in State	143.23	3.32
	TOTAL INPUT	4316.73	Total Losses	143.23	3.32
* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th May 2016 to 24.00'hours of 25th June 2016					
* The Transmission Losses are worked out by using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st April 2016 to 24.00 Hr of 30th April 2016 at 00.30 Hr interval.					
* The SR Losses (External Losses to TSTRANSCO) for the month of April 2016 is 2.868%					
* Cummlative losses at TS-Periphery FY 2016-17 is 3.32 %					