

**TSTRANSCO Transmission Losses for the month of APRIL 2017**

**EBC Data**

INPUT		NET ENERGY in MU	OUTPUT		
			DISCOM	MU	
<b>TSGENCO</b>	<b>TOTAL</b>	<b>1625.73</b>	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1603.05	TSSPDCL	3412.74	
	HYDEL	22.68	TSNPDCL	1379.22	
<b>C.G.S</b>			<b>Total</b>	<b>4791.96</b>	
	CGS ( Injection at TS-Periphery)	<b>2305.79</b>			
<b>CPPs</b>	<b>TOTAL</b>	<b>199.59</b>			
	132KV My Home Cements I & II	17.89			
	HWP	4.44			
	Kesoram	0.00			
	NBFA # 1 & 2	44.11			
	Sitapuram Power Limited	11.97			
	Madhucon SPIL 132 kV Kusumanchi	7.54			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	19.45			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	0.00			
	Krishnaveni sugars	2.28			
	132KV Laxmi Tulasi	4.38			
	Orient Cement 132 kV	0.01			
	NBEIL #1	39.17			
	NBEIL #2	39.40			
	ICL (Rassi Cements)	8.93			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	0.00			
	Anjani Port Land Cement	0.00			
<b>Non-Conventional (132 Kv PDs)</b>	<b>TOTAL</b>	<b>118.10</b>			
	Clean solar	5.43			
	Dayakara Solar (P) Ltd.	5.73			
	Enrich (Solar)	8.73			
	Energon Soleq Pvt Ltd	8.68			
	G.S.R.Sugars Pvt Ltd	-0.05			
	Ganapathi Sugars Ltd.	-0.07			
	Grahati Solar	9.07			
	Kakatiya Cement & Sugar Industries Ltd.	-0.15			
	Karvy solar	2.37			
	My Home Power Ltd. (NGPL)	0.00			
	Mytrah Vayu (Godavari) Pvt. Ltd. (Wind)	12.49			
	NTPC Solar power plant (10MW)	1.35			
	Nizam Deccan Sugars Ltd.	0.00			
	Polepally Solar Park	4.27			
	Renue Akshay Solar Plant	17.56			
	SLS Power Corp. Ltd.	0.50			
	Shravana Power Projects Pvt. Ltd.	1.67			
	Sunborne Energy Tech. (P) Ltd. (Solar)	6.17			
	Win solar	2.81			
	Renew Mega Solar Pvt.Ltd	9.54			
	Renew Saurshakthi Pvt. Ltd.	3.67			
	Renew Solar Plant (Mdk. Dist.)	4.38			
	Ujvalatejas Solaire Urja Pvt. Ltd.	3.33			
	Suprasanna Solar	3.73			
	Winsol solar	6.51	<b>Losses</b>	<b>MU</b>	<b>%</b>
	Renew Solar Energy Pvt. Ltd. (Dichpally)	0.40			
<b>IPPs</b>	Singareni Thermal Power Project Ltd. (Jaipur)	<b>705.90</b>	With in State	163.15	3.29
	<b>TOTAL INPUT</b>	<b>4955.11</b>	<b>Total Losses</b>	<b>163.15</b>	<b>3.29</b>

\* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th May 2017 to 24.00'hours of 25th June 2017

\* The Transmission Losses are worked out by using MRI data.

\* MRI Data considered is from 00.00 Hr of 1st April 2017 to 24.00 Hr of 30th April 2017 at 00.30 Hr interval.

\* The SR Losses (External Losses to TSTRANSCO) for the month of March 2017 is 3.192%

\* Cumulative losses at TS-Periphery FY 2017-18 is 3.29 %