

TSTRANSCO Transmission Losses for the month of AUGUST 2017					
EBC Data					
	INPUT		OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
<b>TSGENCO</b>	<b>TOTAL</b>	<b>1345.87</b>	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1348.54	TSSPDCL	3538.24	
	HYDEL	-2.67	TSNPDCL	1426.36	
<b>C.G.S</b>			<b>Total</b>	<b>4964.60</b>	
	CGS ( Injection at TS-Periphery)	<b>2628.95</b>			
<b>CPPs</b>	<b>TOTAL</b>	<b>154.39</b>			
	132KV My Home Cements I & II	12.70			
	HWP	0.50			
	Kesoram	0.59			
	NBFA # 1 & 2	30.36			
	Sitapuram Power Limited	9.09			
	Madhucon SPIL 132 kV Kusumanchi	0.00			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	12.86			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	0.00			
	Krishnaveni sugars	2.71			
	132KV Laxmi Tulasi	0.03			
	Orient Cement 132 kV	0.01			
	NBEIL #1	35.68			
	NBEIL #2	35.64			
	ICL (Rassi Cements)	13.12			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	1.12			
	Anjani Port Land Cement	0.00			
<b>Non-Conventional (132 Kv PDs)</b>	<b>TOTAL</b>	<b>182.78</b>			
	ACME Medak Solar energy Pvt. Ltd.	6.04			
	ACME PV Powertech Pvt. Ltd. (Sadasivpet)	5.29			
	ACME Rangareddy Solar Power	3.31			
	Clean solar	3.87			
	Dayakara Solar (P) Ltd.	4.69			
	Divine Solren Pvt. Ltd.	6.09			
	Energion Soleq Pvt Ltd	6.41			
	Energion Soleq Solar (Sadasivapet)	6.75			
	Enrich (Solar)	6.42			
	G.S.R.Sugars Pvt Ltd	-0.05			
	Ganapathi Sugars Ltd.	-0.07			
	Grahati Solar	7.46			
	Kakatiya Cement & Sugar Industries Ltd.	-0.10			
	Karvy solar	2.21			
	My Home Power Ltd. (NGPL)	0.00			
	Mytrah Vayu (Godavari) Pvt. Ltd. (Wind)	20.09			
	NTPC Solar power plant (10MW)	0.91			
	Nizam Deccan Sugars Ltd.	0.00			
	Polepally Solar Park	3.46			
	Renew Mega Solar Pvt.Ltd	4.87			
	Renew Saurshakthi Pvt. Ltd.	3.21			
	Renew Solar Energy Pvt. Ltd. (Dichpally)	17.02			
	Renew Solar Plant (Mdk. Dist.)	2.94			
	Renew Solar Pvt Ltd. (Minpur)	6.67			
	Renue Akshay Solar Plant	13.80			
	SLS Power Corp. Ltd.	7.43			
	SUZLON Energy Ltd.	3.28			
	Shapoorji Pallonji Energy Pvt Ltd. (Solar)	4.23			
	Shravana Power Projects Pvt. Ltd.	3.01			
	Sunborne Energy Tech. (P) Ltd. (Solar)	5.45			
	Sunshakthi solar pvt. Ltd.	2.27			
	Suprasanna Solar	2.58			
	Transform Sun Energy 220kV	12.16			
	Ujvalatejas Solaire Urja Pvt. Ltd. (Solar)	2.49			
	Winsol solar	6.32	<b>Losses</b>	<b>MU</b>	<b>%</b>
	Win solar	2.27			
<b>IPPs</b>	Singareni Thermal Power Project Ltd. (Jaipur)	827.69	With in State	175.08	3.41
	<b>TOTAL INPUT</b>	<b>5139.68</b>	<b>Total Losses</b>	<b>175.08</b>	<b>3.41</b>

\* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th Sept 2017 to 24.00'hours of 25th Oct 2017

\* The Transmission Losses are worked out by using MRI data.

\* MRI Data considered is from 00.00 Hr of 1st August 2017 to 24.00 Hr of 31st August 2017 at 00.30 Hr interval.

\* The SR Losses (External Losses to TSTRANSCO) for the month of July 2017 is 2.774%

\* Cummilative losses at TS-Periphery FY 2017-18 is 3.43 %