

TSTRANSCO Transmission Losses for the month of FEBRUARY 2017					
EBC Data					
	INPUT		OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	1534.38	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1438.72	TSSPDCL	3103.35	
	HYDEL	95.66	TSNPDCL	1400.42	
C.G.S			Total	4503.77	
	CGS (Injection at TS-Periphery)	2153.97			
CPPs	TOTAL	147.02			
	132KV My Home Cements I & II	14.54			
	HWP	2.70			
	Kesoram	0.00			
	NBFA # 1 & 2	13.72			
	Sitapuram Power Limited	12.06			
	Madhucon SPIL 132 kV Kusumanchi	8.73			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	9.92			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	0.00			
	Krishnaveni sugars	5.32			
	132KV Laxmi Tulasi	5.78			
	Orient Cement 132 kV	0.01			
	NBEIL #1	31.32			
	NBEIL #2	31.20			
	ICL (Rassi Cements)	11.65			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	0.08			
	Anjani Port Land Cement	0.00			
Non-Conventional (132 Kv PDs)	TOTAL	108.87			
	Clean solar	5.01			
	Dayakara Solar (P) Ltd.	5.88			
	Enrich (Solar)	7.74			
	Energon Soleq Pvt Ltd	2.94			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.07			
	Grahati Solar	8.98			
	Kakatiya Cement & Sugar Industries Ltd.	7.22			
	Karvy solar	1.96			
	My Home Power Ltd. (NGPL)	0.00			
	Mytrah Vayu (Godavari) Pvt. Ltd. (Wind)	13.55			
	NTPC Solar power plant (10MW)	0.32			
	Nizam Deccan Sugars Ltd.	0.00			
	Polepally Solar Park	4.16			
	Renue Akshay Solar Plant	16.94			
	SLS Power Corp. Ltd.	2.62			
	Shravana Power Projects Pvt. Ltd.	3.86			
	Sunborne Energy Tech. (P) Ltd. (Solar)	6.40			
	Win solar	2.76			
	Renew Mega Solar Pvt.Ltd	2.89			
	Renew Saurshakthi Pvt. Ltd.	0.63			
	Renew Solar Plant (Mdk. Dist.)	4.04			
	Ujvalatejas Solaire Urja Pvt. Ltd.	3.35			
	Suprasanna Solar	3.33			
	Winsol solar	4.43	Losses	MU	%
IPPs	Singareni Thermal Power Project Ltd. (Jaipur)	715.65	With in State	156.13	3.35
	TOTAL INPUT	4659.90	Total Losses	156.13	3.35
* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th March 2017 to 24.00'hours of 25th April 2017					
* The Transmission Losses are worked out by using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st February 2017 to 24.00 Hr of 28th February 2017 at 00.30 Hr interval.					
* The SR Losses (External Losses to TSTRANSCO) for the month of February 2017 is 2.56%					
* Cumulative losses at TS-Periphery FY 2016-17 is 3.35 %					