

TSTRANSCO Transmission Losses for the month of May 2016					
EBC Data					
	INPUT		OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	1354.30	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	1350.06	TSSPDCL	2789.27	
	HYDEL	4.23	TSNPDCL	895.80	
C.G.S			Total	3685.07	
	CGS (Injection at TS-Periphery)	2269.96			
CPPs	TOTAL	156.64			
	132KV My Home Cements I & II	12.11			
	HWP	2.99			
	Kesoram	0.13			
	NBFA # 1 & 2	34.89			
	Sitapuram Power Limited	20.82			
	Madhucon SPIL 132 kV Kusumanchi	5.06			
	BPL 132 kV Sitharampatnam	0.00			
	Penna Power Limited 132KV Ganeshpahadu #1 & 2	11.40			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	2.24			
	Krishnaveni sugars	3.72			
	132KV Laxmi Tulasi	1.74			
	Orient Cement 132 kV	0.08			
	NBEIL #1	26.91			
	NBEIL #2	26.83			
	ICL (Rassi Cements)	7.31			
	PSR Green Power Proj. pvt. Ltd.	0.00			
	Deccan cements	0.40			
Non-Conventional (132 Kv PDs)	TOTAL	32.31			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.08			
	Kakatiya Cement & Sugar Industries Ltd.	-0.13			
	Nagarjuna Green Power Ltd. (NGPL)	0.00			
	Mytrah Vayu (Godavari) Pvt. Ltd. (Wind)	13.10			
	Nizam Deccan Sugars Ltd.	0.00			
	SLS Power Corp. Ltd.	-0.07			
	Shravana Power Projects Pvt. Ltd.	-0.02			
	Enrich (Solar)	7.13			
	Sunborne Energy Tech. (P) Ltd. (Solar)	6.56			
	Karvy solar	1.51			
	Polepally Solar Park	0.00			
	Renue Akshay Solar Plant	3.81	Losses	MU	%
	NTPC Solar power plant (10MW)	0.56			
IPPs	Singareni Thermal Power Project Ltd. (Jaipur)	-0.11	With in State	128.03	3.36
	TOTAL INPUT	3813.10	Total Losses	128.03	3.36

* Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th June 2016 to 24.00'hours of 25th July 2016

* The Transmission Losses are worked out by using MRI data.

* MRI Data considered is from 00.00 Hr of 1st May 2016 to 24.00 Hr of 31st May 2016 at 00.30 Hr interval.

* The SR Losses (External Losses to TSTRANSCO) for the month of May 2016 is 2.789%

* Cummilative losses at TS-Periphery FY 2016-17 is 3.34 %